

Tarpорley Community Centre - Monthly hot & cold water flushing checksheet

Revision date 3 May 21

Distribution: Mgmt committee, Website

Date checked: 11/22 Name of checker: Chad

Monthly hot and cold water temp checking schedule	hot tap flush for 3 min, record temp degC	cold tap flush for 3 min record temp degC	Toilet flush OK?	Any signs of water leaks?	Comments
Committee room sink	OK	OK	n/a	no	Far sentinal
Committee room WHB	OK	OK	n/a	/	
Mens toilet WHB left	OK	OK	n/a		
Mens toilet WHB right	OK	OK	n/a		
Mens toilet W/C	n/a	n/a	/		
Ladies toilet WHB left	OK	OK	n/a		
Ladies toilet WHB right	OK	OK	n/a		
Ladies toilet w/c left	n/a	n/a	/		
Ladies toilet w/c centre	n/a	n/a	/		
Ladies toilet w/c right	n/a	n/a	/		
Cleaners cupboard sink	/	/	n/a		
Accessible toilet WHB and W/C	OK	OK	n/a		With TMV
Main kitchen sink	OK	OK	n/a		Near sentinal
AM kitchen	OK	OK	n/a		
AM mens toilet WHB and W/C	OK	OK	/		
AM ladies toilet WHB and W/C	OK	OK	/	Far sentinal	
CR accessible toilet WHB and W/C	OK	OK	/	With TMV	
CR kitchen sink	OK	OK	n/a	Near sentinal	
CR west toilet (nearer High St) WHB and W/C	OK	OK	/	Far sentinal	
CR west toilet (nearer CR) WHB and W/C	/	/	/	cleaner store	

Notes: For protection against legionella bacteria hot water temps to be above 50C except TMV to be above 40C; cold water temps to be below 20C