

Portable Appliance Test Record

This record applies to TCC owned appliances. These are visually inspected every week and fully tested every 6 months due to heavy use by multiple users

Name of tester Tony Fealer Date: 00 Aug 2020 Distribution: Trustees, website

Appliance	Location	Class (note 1)	Fuse rating Amp	Visual inspect result P/F? (note 2)	PAT result P/F? (note 3)	Overall result P/F?	Sticker applied P=green F=red	Comments
Robothem work bit	Kitchen	1	13	P	P	P	Green	
Philips kettle	"	1	13	P	P	P	Green	
Bosch kettle	"	1	13	P	P	P	Green	
TECO kettle	"	1	13	P	P	P	Green	
Grease tender	"	1	13	P	P	P	Green	
SHARP microwave	"	1	13	P	P	P	Green	leakage < 5mm/cm ²
SECO fridge	"	1	3	P	P	P	Green	
TESCO ext. cable	store	2	2/A	P	P	P	Green	
Maple ext. cable	store	2	2/A	P	P	P	Green	
Workzone ext. cable	store	2	2/A	P	P	P	Green	
Swan work heater	AM kit	1	13	P	P	P	Green	
Wilko kettle (red)	AM kit	1	13	P	P	P	Green	
Henry (red) nose	CR	2	13	P	P	P	Green	
Abode microwave	CR	1	13	P	P	P	Green	leakage < 5mm/cm ²
Cookwell microwave	CR	1	13	P	P	P	Green	leakage < 5mm/cm ²
Cygnal work heater	CR	1	13	P	P	P	Green	
Fridge LEC	CR	1	3	P	P	P	Green	
Elec connector HV	CR store	1	13	P	P	P	Green	
Elec connector HV	CR store	1	13	P	P	P	Green	
Elec connector HV	CR store	1	13	P	P	P	Green	
Elec connector HV	CR store	1	13	P	P	P	Green	

- Notes:
1. Class 1 requires an earth connection, Class 2 is double insulated
 2. Visual inspection includes plug outside, plug inside including correct fuse rating, appliance body, appliance cable
 3. Full PAT covers earth continuity, insulation resistance and polarity (for cables)