

Portable Appliance Test Record

This record applies to TCC owned appliances. These are visually inspected every week and fully tested every 6 months due to heavy use by multiple users

Name of tester Ken wood Date: 2.11.23

Distribution: Trustees, website

Appliance	Location	Class (note 1)	Fuse rating Amp	Visual inspect result P/F? (note 2)	PAT result P/F? (note 3)	Overall result P/F?	Sticker applied P=green F=red	Comments
2 gang extension lead	locked cupboard			P	F	F	R	One socket faulted
Fan heater	-11-			P	P	P	P	
Fan heater	-11-			P	P	P	P	
STIR FLOW CONVEYOR HEATER	CR ROOM	1		P	P	P	P	
STIR FLOW CONVEYOR HEATER	CR ROOM	1		P	P	P	P	
BRQ CONVEYOR HEATER	CR ROOM	1		P	P	P	P	
BRQ CONVEYOR HEATER	CR ROOM	1		P	P	P	P	

- Notes:
- Class 1 requires an earth connection, Class 2 is double insulated
 - Visual inspection includes plug outside, plug inside including correct fuse rating, appliance body, appliance cable
 - Full PAT covers earth continuity, insulation resistance and polarity (for cables)