

BARLOWS

Barlows (UK) Ltd Fire & Security

Clifford House, Hampton Heath Industrial Estate, Malpas, Cheshire

Telephone: 03303110999 Fax: 01948 820232

www.barlowsuk.co.uk Email: fireandsecurity@barlowsuk.co.uk



Job Number	F0022387/001	Corrective Maintenance Report
-------------------	---------------------	--------------------------------------

Customer: Tarporley Community Centre	Genuine Alarm Activation <input type="checkbox"/>	Date: 19/08/2019 11:18	Serial No.: F0022387/001
Address Tarporley Community Centre, High Street, Tarporley, Cheshire, CW6 0AY	False Alarm Activation <input type="checkbox"/>	Is the system under contract ? Yes Out of Hours ? No	
	N/A <input checked="" type="checkbox"/>		

<input type="checkbox"/> INTRUDER	<input type="checkbox"/> FIRE	<input type="checkbox"/> CCTV	Circuit Number: N/A Circuit Location: No Device Type: No Device Model: No
<input type="checkbox"/> ACCESS	<input checked="" type="checkbox"/> EM-LIGHTING	<input type="checkbox"/> N/A	
Reported Fault: *PARTS ALLOCATED TO ENGINEER SHELF* Replace failed emergency lighting and extinguishers 10no LED B/H 3no Exit boxes 1no 2kg co2 2no 6L foam			

Cause of Callout	1. CUSTOMER RELATED <input type="checkbox"/>	2. COMPANY RELATED <input checked="" type="checkbox"/>	3. LINE FAULT RELATED <input type="checkbox"/>
------------------	--	--	--

Further detail and action taken: Replaced 13 EML fittings following recent service (10 x bulkhead, 3 x exit sign)
 Replaced 2 x 6ltr foam and 1 x 2KG CO2 extinguisher following recent service.
 Relocated CO2 extinguisher in boiler room at customer request.
 All ok

Amendment / Permanent Changes:	Temporary Disconnection:
--------------------------------	--------------------------

Further Action Required: No	Reset Yes/No:
	Method of Resetting:
	Charge Yes/No:

Arc Account Number: N/A	SYSTEM	TIME	Specification Amended: No <input type="checkbox"/>
	OFF WATCH	08:10	
Historical Record Updated: No	ON WATCH	12:30	

Materials Used:	Item	Quantity
	LED Bulkhead	10
	LED Exit box	3
	6ltr AFFF Foam extinguisher	2
	2KG CO2 extinguisher	1
	CO2 banging bracket	1
	Extinguisher tamper seal	3

Time of request (if known):	Time arrival: 08:38	Time depart: 12:18
-----------------------------	---------------------	--------------------

BARLOWS

Barlows (UK) Ltd Fire & Security

Clifford House, Hampton Heath Industrial Estate, Malpas, Cheshire

Telephone: 03303110999 Fax: 01948 820232

www.barlowsuk.co.uk Email: fireandsecurity@barlowsuk.co.uk



Job Number

F0022387/001

Corrective Maintenance Report

The system has been left in full working order apart from the items and/or disconnections listed below:

Technician's
Signature

Customer's
Signature