

BARLOWS

Barlows (UK) Ltd Fire & Security

Clifford House, Hampton Heath Industrial Estate, Malpas, Cheshire

Telephone: 03303110999 Fax: 01948 820232

www.barlowsuk.co.uk Email: fireandsecurity@barlowsuk.co.uk



Job Number	M0708663	Emergency Light Testing Certificate
-------------------	----------	--

Customer	Tarpoley Community Centre				
Address	High Street, Cheshire,				
Postcode	CW6 0AY				
Site	Tarpoley Community Centre				
Address	High Street, Cheshire,				
Postcode	CW6 0AY				
Type of Service	Periodic	Frequency of Visits	Six Monthly	Duration of this test	3 Hours

Purpose Of Lighting

Emergency Escape	Yes	Escape Route	Yes	Open Area Lighting	Yes	High Risk Task	No
-------------------------	-----	---------------------	-----	---------------------------	-----	-----------------------	----

Type Of Lighting

Self Contained Emergency Luminaires	Yes	Central Battery System	No
Combined Emergency Luminaires	No	Standby Generator System	No

Quantities

Self Contained Emergency Luminaires	33	Central Battery System	NA
Combined Emergency Luminaires	0	Standby Generator System	NA

Requirement	Relevant BS5266-1 2011 Clause	Result
P1- Under Test Conditions, adequate ** Illumination provided for safe movement on the escape route and the open areas	5	Yes
P2- All escape safety signs and fire fighting, equipment location signs visible with normal extinguished	5.4	Yes
P3- Emergency circuits correctly segregated from other supplies	8.2.6	Yes
P4- System has a suitable test facility for the application	8.3.3	Yes
P5- Test records in the log book complete and satisfactory	11	NA
P6- Luminaires clean and undamaged with lamps in good condition	12	Yes
P7- Evidence of servicing of Central Battery System (In line with manufacturers procedures) ; in house or current maintenance contract is in place	12.1	NA
P8- Evidence of servicing of standby generator system (in line with manufacturers procedures) ; in house or current maintenance contract is in place	12.2	NA
P9- After test, the charging indicators operate correctly	12.3	Yes

The following items were found to be defective and were resolved at the point of service:

Rectified lighting failures found on PPM visit 13/8/2018

The following items were found to be in need of actioning in order for the system to comply to BS5266-1:2011

Arrival Time / Date	Departure Time /Date
15/08/2018 10:30	15/08/2018 15:15

BARLOWS


Barlows (UK) Ltd Fire & Security

Clifford House, Hampton Heath Industrial Estate, Malpas, Cheshire

Telephone: 03303110999 Fax: 01948 820232

www.barlowsuk.co.uk Email: fireandsecurity@barlowsuk.co.uk



Job Number	M0708663	Emergency Light Testing Certificate	
		Engineer	Josh Bonfield
I declare that I am a Competent Person(CP) in emergency lighting system maintenance. All equipment returned to normal. Serviced according to BS5266-1:2011			
Accepted, for and behalf of the user, by the Responsible Person (RP), I understand that the system is operating as designed. I understand that if any items, were shown to be defective, the emergency lighting system may not comply with BS 5266		Customer	Tony yeates