



Non Domestic Gas Safety Record



This inspection is for gas safety purposes only in accordance with Gas Safety (Installation and Use) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the Flue integrity, construction and lining has not been carried out.

Form Serial Number: FRM/P0007747

Registered Business Details: GAS SAFE NO: **L9e-**

Gas Operative : Craig Swinden

Name : Barlows UK Ltd Plumbing and Heating

Address : Marjorie House, Watts Street
Chadderton, Oldham

PostCode : OL9 9LQ Telephone : 0161 6281047

Job Address:

Name : Tarporley Community Centre Contact : Tony Yeates
Address : High Street, Tarporley
Cheshire,
PostCode : CW6 0AY Telephone : 07708 098730
URN :

Client Landlord's Details:

Name : Tarporley Community Centre
Address : High Street, Tarporley
Cheshire,
PostCode : CW6 0AY Telephone : 01829 730136
Rented Accommodation : Yes No of appliance tested : 4
Visual check to ensure burner pressure + FGAS test points have been replaced? Yes

Appliance Details

Inspection Details

Location	Type	Make	Model	Landlords Appliance	Appliance Inspected	Flue Type	Operating Pressure	Device Correct Operation	Ventilation Provision Satisfactory	Visual Condition of Flue	Termination Satisfactory	Flue Performance Check	CO PPM	CO2%	CO/CO2 Ratio	Spillage Test	Appliance Serviced	Safe To Use
1 Disabled toilets	Gas combi boiler	Worcester	28i junior greenstar	Yes	Yes	RS	27 kW/h	Yes	N/A	Pass	Pass	N/A	65	9.4	0.0006	N/A	No	Yes
2 Plant	Gas boiler	Worcester	24i system boiler	Yes	Yes	RS	23 kW/h	Yes	N/A	Pass	Pass	N/A	54	9.5	0.0006	N/A	No	Yes
3 Plant Room	Gas water heater	Andrews	25/49	Yes	Yes	OF	8 Mbars	Yes	Yes	Pass	Pass	Pass	27	8.6	0.0003	Pass	No	Yes
4 Plant Room	Gas boiler	Potterton	Ec two 90	Yes	Yes	OF	76 kW/h	Yes	Yes	Pass	Pass	N/A	14	8.8	0.0001	N/A	No	Yes



Defect Details

Appliance #	Defect Identified	Remedial Action	Warning Label Fitted	Warning Issued	Warning Note Serial No
1					
2					
3					

Smoke/ CO Alarm Details

Location	Type	Approved Alarm Fitted	Alarm Expiry	Testing of Alarm Satisfactory	Battery/ Hard wired	Replacement Required
1						
2						

Gas installation pipework satisfactory visual inspection Yes
Emergency control accessible Yes
Satisfactory gas tightness test Yes
Equipotential bonding satisfactory Yes

This safety record is issued by: Signed  Printed name Craig Swinden
Received by: Tony Yeates 
Date: 07-Aug-2018