

**Tarporley Community Centre - Monthly hot & cold water flushing checksheet**

Revision date 4 Aug 2020

Distribution: Mgmt committee, Website

Date checked: 2/12/20

Name of checker: Tony Feala

Monthly hot and cold water temp checking schedule	hot tap flush for 3 min, record temp degC	cold tap flush for 3 min record temp degC	Toilet flush OK?	Any signs of water leaks?	Comments
Committee room sink	OK	OK	OK	No	
Committee room WHB	OK	OK	OK	No	
Mens toilet WHB1	OK	OK	OK	No	
Mens toilet WHB2	OK	OK	OK	No	
Ladies toilet WHB1				No	out of service
Ladies toilet WHB2				No	out of service
Cleaners cupboard sink	OK	OK	OK	No	
Accessible toilet WHB	OK	OK	OK	No	
Main kitchen sink	OK	OK	OK	No	
AM kitchen	OK	OK	OK	No	
AM mens toilet WHB	OK	OK	OK	No	
AM ladies toilet WHB	OK	OK	OK	No	
CR accessible toilet WHB	OK	OK	OK	No	
CR kitchen sink	OK	OK	OK	No	
CR west toilet (nearer High St) WHB				No	out of service
CR west toilet WHB (nearer CR)				No	out of service

Notes: For protection against legionella bacteria hot water temps to be above 50C except TMV to be above 40C; cold water temps to be below 20C

Expires 2/12/21.